CHEMTROL AUSTRALIA PTY LTD
ABN: 95 626 805 301
sales@chemtrol.com.au
1300 585 820

CHEMTROL® programmable series (PC) controllers
Wired connection setup

1. Destination host: CHEMTROL® webserver communication page.
   Please allow three link connections (URL).
   a. https://au.sa2.us
   b. https://sa2.us
   c. https://sa3.us

2. Firewall: Please make sure the controller is connected to the LAN with an open access to the WEB through the local firewall port #10004.

3. The controller has DHCP setup and should detect the IP address automatically once connection has been established. Screenshot attached below.

4. Local wired connection: If DHCP is not an applicable, please change the DHCP setup to NO and add manually the following numbers:
   a. IP address
   b. Subnet Mask
   c. Default IP Gateway
   d. DNS

Turn the controller off, and then back on. That's it!
The controller should now be connected.



Please let us know if further assistance is required. We are always happy to help!
CHEMTROL® technical team.